


## Declaration of Conformity

We, the undersigned

Company	CONTRIVE S.r.l.
Address, City	Via Enrico Fermi 18 24040 Suisio (Bergamo)
Country	Italy
Phone number	+39 35 4948236
E-mail address	info@contrive.it



### CERTIFY AND DECLARE UNDER OUR SOLE RESPONSIBILITY THAT THE FOLLOWING EQUIPMENT

<b>Product description</b>	BURNER CONTROL UNIT
<b>Type</b>	QBK FAMILY
<b>P.I.N.</b>	0063CS1560
<b>Manufacturer</b>	CONTRIVE S.r.l.
<b>Technology</b>	Complex electronic
<b>Electrical supply</b>	115/230 Vac 50/60 Hz
<b>Gas valve output</b>	250Vac / max 2A / cosφ =0.7
<b>IP protection degree</b>	IP64 ALUMINIUM / IP67 PLASTIC
<b>Ambient temperature</b>	-20 to +60 °C
<b>Fuel type</b>	Gas and/or Oil
<b>Flame detection</b>	Ionization or UV
<b>Burner control Class</b>	C
<b>Reset function Class</b>	B
<b>Pollution degree</b>	1 or 2 (EN60730-1:2022)
<b>Available Types</b>	QBK / QPK – Aluminum / Plastic – FULL QBB / QPB – Aluminum / Plastic – BASIC QBD / QPD – Aluminum / Plastic – DUAL QBM / QPM – Aluminum / Plastic – MINI



is tested to and conforms with the relevant **Union harmonization legislation**:

- Gas Appliances Regulation (EU) 2016/426 – GAR
- Low Voltage Directive (EU) 2014/35 – LVD
- Electromagnetic Compatibility Directive (EU) 2014/30
- Restriction of Hazardous Substances Directive (EU) 2011/65 – RoHS
- Registration, Evaluation, Authorization and Restriction of Chemicals (EU) Regulation 1907/2006 – REACH

The following **harmonized standards and technical specification** have been applied:

- EN298:2022

<b>Basic risk evaluated</b>	<b>Safety functions</b>
Explosion	Controlling ON-OFF gas valves
Fire	Safety timing and non-volatile lockout Flame supervision Local and remote reset function
Poisoning (combustion gases)	Air supervision (QBK/QPK – FULL version only)
Hot surfaces	Not applicable
Exposure to harmful substances	Not applicable

Installation and fitting instructions supplied with the product and available for download: <https://www.burner-control.com/E/QBK.php>

NOTIFIED BODY: 0063 - KIWA Nederland B.V. – Certificate number: 18GR0758/01 valid until 28/05/2035

Suisio, April 4<sup>th</sup> 2025

**CONTRIVE S.r.l.**  
Via Enrico Fermi 18  
I-24040 Suisio (Bergamo)

Giovanni Pedruzzi  
CEO/CTO